



3 November 2016

Ref: 30083/JV/gb

**Contact: John Vanderzon**  
**Phone: +61 8 8274 2188**  
**E-mail: [jvanderzon@aga.asn.au](mailto:jvanderzon@aga.asn.au)**

Mr Gunjan Pancholi  
Global Supply Line Pty Ltd  
69-71 Barndioota Road  
Salisbury Plain, SA 5109

Dear Mr Pancholi,

**Re: Global Supply Line - JC Ball Valves**  
**Series: 515/530, (Class 150/300), Full Bore**  
**Series: 715/730, (Class 150/300), Reduced Bore**  
**AGA Application 15161**

Further to our email dated 15 September 2016 (in response to our Test report R150427010) and further receipt of specification information up to 29 September 2016, I confirm our Laboratory has now completed a Laboratory Specification Verification (LSV) on samples relating to the product mentioned above.

The LSV has been completed satisfactorily and supplied drawings and technical information has been used as the basis for our certification files. All work for this project is now complete and I am pleased to enclose the following:

- AGA Certificate **8328**.
- Appliance Specification Issue **01**.
- Details of the certification entry as it will appear in the "Directory of AGA Certified Products", as found on our website [www.aga.asn.au](http://www.aga.asn.au).
- Our invoice covering the certification fee for this project.

Please review the enclosed documentation and advise if any details are incorrect or inadequate.

Yours sincerely,

A handwritten signature in black ink that reads 'John Vanderzon'.

John Vanderzon  
**Client Manager, AGA**

# AGA CERTIFIED PRODUCT



[www.jas-anz.org/register](http://www.jas-anz.org/register)

Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **86 008 134 512**

Manufacturer: **JC FABRICA DE VALVULAS S.A., SPAIN**

Agent (if applicable): **N/A**

Type of Component: **MANUAL BALL VALVES**

Model No. & Description: **JC BALL VALVES**  
**515/530 SERIES (CLASS 150/300)**  
**715/730 SERIES (CLASS 150/300)**  
Pressure rating:  
Class 150 - 2000kPa, Class 300 - 5100kPa  
Temperature rating: 0 to 100°C  
Body material:  
Carbon steel (AIT) or Stainless Steel (IIT)  
Seat material: PTFE  
Nominal sizes:  
DN15, 20, 25, 40, 50, 65, 80, 100 & 150

(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)

Relevant Standard(s): **AS 4617-2004 (Incorporating Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

## This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.





**Client Manager**



**Certificate Authorised**

Certificate first issued: **3 November 2016**

Certificate No: **8328**

This copy valid from: **3 November 2016**

Refer specification issue: **01**

QF714/11

# Directory Certificate Entry

## Components

### Manual Shut-Off Valves

#### Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(69-71 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2004 Amdt 1 | Manual Shut-Off Gas Valves | 9/03/2011

## JC

8328 11.16

### JC Manual Ball Valves

515/530 Series (Class 150/300)

715/730 Series (Class 150/300)

### kPa Rating

see note

see note

Pressure rating: Class 150 - 2000kPa, Class 300 - 5100kPa

Temperature rating: 0°C to 100°C

Body material: Carbon steel (AIT) or Stainless Steel (IIT)

Seat material: PTFE


Nominal sizes: DN15, 20, 25, 40, 50, 65, 80, 100, 150

Thursday, 3 November 2016

# AGA CERTIFIED PRODUCT



JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)

Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **86 008 134 512**

Manufacturer: **JC FABRICA DE VALVULAS S.A., SPAIN & AIR TORQUE, ITALY**

Agent (if applicable): **N/A**

Type of Component: **AUTOMATIC SHUT OFF VALVES**

Model No. & Description: **JC BALL VALVES + AIR TORQUE ACTUATORS  
515/530 SERIES (CLASS 150/300)  
715/730 SERIES (CLASS 150/300)**  
Pressure rating:  
Class 150 - 2000kPa, Class 300 - 5100kPa  
Temperature rating: 0 to 100°C  
Body material:  
Carbon steel (AIT) or Stainless Steel (IIT)  
Seat material: PTFE  
Nominal sizes:  
DN15, 20, 25, 40, 50, 65, 80, 100 & 150

(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)

Relevant Standard(s): **AS4629-2005 (Incorporating Amendment No 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

## This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



*John Vanderz...*

**Client Manager**

*[Signature]*

**Certificate Authorised**

Certificate first issued: **5 April 2017**

Certificate No: **8329**

This copy valid from: **5 April 2017**

Refer specification issue: **01**

QF714/11

# Directory Certificate Entry

Components

Automatic Shut Off Valves

Class I

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s: *AS 4629 | 2005 Amdt 1 | Automatic shut-off valves and vent valves | 30/03/2007*

**JC**

| 8329 | 4.17 Nominal<br>Size mm | Connections<br>In | Designation  | Rated<br>kPa | Oper<br>Posn |
|------|-------------------------|-------------------|--|--------------|--------------|
|      |                         |                   | Automatic Shut-Off Valves - Ball Valves & Air Torque Actuators |              |              |
|      |                         |                   | 515/530 Series (Class 150/300)                                 | see note     |              |
|      |                         |                   | 715/730 Series (Class 150/300)                                 | see note     |              |

*Pressure rating: Class 150 - 2000kPa, Class 300 - 5100kPa*

*Temperature rating: 0 to 100°C*

*Body Material: Carbon Steel (AIT) or Stainless Steel (IIT)*

*Seat Material: PTFE*

*Nominal Sizes: DN15, 20, 25, 40, 50, 65, 80, 100 & 150*

**Wednesday, 5 April 2017**