

# AGA CERTIFIED PRODUCT



JAS-ANZ



www.jas-anz.org/register

Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **86 008 134 512**

Manufacturer: **JC FABRICA DE VALVULAS S.A., SPAIN & AIR TORQUE, ITALY**

Agent (if applicable): **N/A**

Type of Component: **AUTOMATIC SHUT OFF VALVES**

Model No. & Description: **JC BALL VALVES + AIR TORQUE ACTUATORS  
515/530 SERIES (CLASS 150/300)  
715/730 SERIES (CLASS 150/300)**  
Pressure rating:  
Class 150 - 2000kPa, Class 300 - 5100kPa  
Temperature rating: 0 to 100°C  
Body material:  
Carbon steel (AIT) or Stainless Steel (IIT)  
Seat material: PTFE  
Nominal sizes:  
DN15, 20, 25, 40, 50, 65, 80, 100 & 150

(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)

Relevant Standard(s): **AS4629-2005 (Incorporating Amendment No 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

## This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



*John Vanderz...*

**Client Manager**

*[Signature]*

**Certificate Authorised**

Certificate first issued: **5 April 2017**

Certificate No: **8329**

This copy valid from: **5 April 2017**

Refer specification issue: **01**

QF714/11

# Directory Certificate Entry

Components

Automatic Shut Off Valves

Class I

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s: *AS 4629 | 2005 Amdt 1 | Automatic shut-off valves and vent valves | 30/03/2007*

**JC**

8329	4.17 Nominal Size mm	Connections In	Designation	Rated kPa	Oper Posn
			Automatic Shut-Off Valves - Ball Valves & Air Torque Actuators		
			515/530 Series (Class 150/300)	see note	
			715/730 Series (Class 150/300)	see note	

*Pressure rating: Class 150 - 2000kPa, Class 300 - 5100kPa*

*Temperature rating: 0 to 100°C*

*Body Material: Carbon Steel (AIT) or Stainless Steel (IIT)*

*Seat Material: PTFE*

*Nominal Sizes: DN15, 20, 25, 40, 50, 65, 80, 100 & 150*

**Wednesday, 5 April 2017**