



3 November 2016

Ref: 30083/JV/gb

Contact: John Vanderzon
Phone: +61 8 8274 2188
E-mail: jvanderzon@aga.asn.au

Mr Gunjan Pancholi
Global Supply Line Pty Ltd
69-71 Barndioota Road
Salisbury Plain, SA 5109

Dear Mr Pancholi,

Re: Global Supply Line - JC Ball Valves
Series: 515/530, (Class 150/300), Full Bore
Series: 715/730, (Class 150/300), Reduced Bore
AGA Application 15161

Further to our email dated 15 September 2016 (in response to our Test report R150427010) and further receipt of specification information up to 29 September 2016, I confirm our Laboratory has now completed a Laboratory Specification Verification (LSV) on samples relating to the product mentioned above.

The LSV has been completed satisfactorily and supplied drawings and technical information has been used as the basis for our certification files. All work for this project is now complete and I am pleased to enclose the following:

- AGA Certificate **8328**.
- Appliance Specification Issue **01**.
- Details of the certification entry as it will appear in the "Directory of AGA Certified Products", as found on our website www.aga.asn.au.
- Our invoice covering the certification fee for this project.

Please review the enclosed documentation and advise if any details are incorrect or inadequate.

Yours sincerely,

John Vanderzon
Client Manager, AGA

AGA CERTIFIED PRODUCT



www.jas-anz.org/register

Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **86 008 134 512**

Manufacturer: **JC FABRICA DE VALVULAS S.A., SPAIN**

Agent (if applicable): **N/A**

Type of Component: **MANUAL BALL VALVES**

Model No. & Description: **JC BALL VALVES**
515/530 SERIES (CLASS 150/300)
715/730 SERIES (CLASS 150/300)
Pressure rating:
Class 150 - 2000kPa, Class 300 - 5100kPa
Temperature rating: 0 to 100°C
Body material:
Carbon steel (AIT) or Stainless Steel (IIT)
Seat material: PTFE
Nominal sizes:
DN15, 20, 25, 40, 50, 65, 80, 100 & 150

(Refer www.aga.asn.au for more details)

Relevant Standard(s): **AS 4617-2004 (Incorporating Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.





Client Manager



Certificate Authorised

Certificate first issued: **3 November 2016**

Certificate No: **8328**

This copy valid from: **3 November 2016**

Refer specification issue: **01**

QF714/11

Directory Certificate Entry

Components

Manual Shut-Off Valves

Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(69-71 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2004 Amdt 1 | Manual Shut-Off Gas Valves | 9/03/2011

JC

8328 11.16

JC Manual Ball Valves

515/530 Series (Class 150/300)

715/730 Series (Class 150/300)

kPa Rating

see note

see note

Pressure rating: Class 150 - 2000kPa, Class 300 - 5100kPa

Temperature rating: 0°C to 100°C

Body material: Carbon steel (AIT) or Stainless Steel (IIT)

Seat material: PTFE

Nominal sizes: DN15, 20, 25, 40, 50, 65, 80, 100, 150

Thursday, 3 November 2016

18 March 2019

Ref: 31600/JV/QL

Contact: John Vanderzon
Phone: +61 8 8274 2188
E-mail: jvanderzon@aga.asn.au



Mr Gunjan Pancholi
Global Supply Line Pty Ltd
1-23 Barndioota Road
Salisbury Plain, SA 5109

Dear Mr Pancholi,

**Re: Global Supply Line - JC Ball Valves + Air Torque actuators
Update of Certification documents
AGA Application 16988, AGA Certificate 8329**

I refer to your Application for Modification received on 6 March 2019 and our further correspondence. This Application is for changes to product already certified under coverage of AGA certification **8329**, and the modifications/variations concern update of the certification documents, to include an itemised listing of the ancillary Actuator Control Components.

In support of your application I acknowledge;

- Your advice the ancillary items have always been supplied with the actuated valve assemblies.
- Receipt of technical literature for the ancillary items, to be added to our certification file.

Following a review of our files I confirm that no additional assessment is required. This update is considered a minor technical change to documentation held in our certification file, and there is no change to the product certified. The specification held in our certification file has been updated to add the technical literature for the ancillary items.

All work for this project is now complete and I am pleased to enclose the following:

- Revised AGA Certificate 8329.
- Revised Appliance Specification Issue 03.
- Details of the certification entry as it will appear in the "Directory of AGA Certified Products", as found on our website www.aga.asn.au.

Please review the enclosed documentation and advise if any details are incorrect or inadequate.

Yours sincerely,

A handwritten signature in black ink that reads "John Vanderzon".

John Vanderzon
Client Manager, AGA



AGA CERTIFIED PRODUCT



Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **86 008 134 512**

Manufacturer: **JC FABRICA DE VALVULAS S.A., SPAIN & AIR TORQUE, ITALY**

Agent (if applicable): **N/A**

Type of Component: **AUTOMATIC SHUT OFF VALVES AND VENT VALVES**

Model No. & Description: **JC BALL VALVES + AIR TORQUE ACTUATORS
515/530 SERIES (CLASS 150/300)
715/730 SERIES (CLASS 150/300)**

Nominal sizes: DN15, 20, 25, 40, 50, 65, 80, 100 & 150
Pressure & Temperature rating: Class 150 - 2000kPa @ 38°C, Class 300 - 5100kPa @ 38°C
Body material: Carbon steel (AIT) or Stainless Steel (IIT)
Seat material: PTFE

Ancillary Actuator Control Components:

Solenoid valves: ASCO 551, 314 or 327 Series or Burkert 6518 or 6519 Series
Limit switches: ITS Series
Quick exhaust valves (optional if required): Numatics SEV or ASCO MV27 Series

(Refer www.aga.asn.au for more details)

Relevant Standard(s): **AS4629-2005 (Incorporating Amendment No 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



John Vanderz

Client Manager

[Signature]

Certificate Authorised

Certificate first issued: **5 April 2017**

Certificate No: **8329**

This copy valid from: **18 March 2019**

Refer specification issue: **03**

Directory Certificate Entry

Components

Automatic Shut Off and Vent Valves

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4629 | 2005 Amdt 2 | Automatic shut off valves and vent valves | 21/12/2016

JC

8329	4.17 Nominal Connections	Designation	Rated kPa	Oper Posn	Valve Class
	Size mm In				
	Automatic Shut-Off Valves & Vent Valves				
	JC Ball Valves & Air Torque Actuators				
		515/530 Series (Class 150/300)	see note		
		705/730 Series (Class 150/300)	see note		

Nominal sizes: DN15, 20, 25, 40, 50, 65, 80, 100 & 150

Pressure rating: Class 150 - 2000kPa @ 38°C, Class 300 - 5100kPa @ 38°C

Body material: Carbon steel (AIT) or Stainless Steel (IIT)

Seat material: PTFE

Ancillary Actuator Control Components:

Solenoid Valves: ASCO 551, 314 or 327 series or Burkert 6518 or 6519 Series

Limited switches: ITS Series

Quick exhaust valves (optional if required): Numatics SEV or ASCO MV27 Series

Tuesday, 19 March 2019